



Marking to ATEX 94/9/EC Directive: Ex II 2 G Ex d IIC Gb / II 2 D Ex tb IIIC Db IP66

Zone: 1, 2, 21, 22 , Gas Group IIC

Compliance with: IEC 60079-0 : 2007, IEC 60079-1 : 2007, IEC 60079-31 : 2008

EC Type Examination Certificate: ISSeP 10 ATEX 002U



FEATURES

- 90° elbows are used in electrical conduit installations to change direction.
- Certified nipples are used with Female/Female elbows to obtain Female/Male or Male/Male entries.
- Sizes and standard thread available are 1/2" to 4" NPT. Other threads supplied on request.
- Material: copper free aluminium alloy.



Female/Female



Male/Female



Male/Male

SIZE REF.	NME1	NME2	NME3	NME4	NME5	NME6	NME7	NME8	NME9
INCH NPT	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"	2 1/2"	3"	4"

ORDERING INFORMATION

Specify size reference and thread form (NPT, ISO metric, ...)

Male or Female entries.

Example: For 1/2" NPT Male/Female elbow: NME1 / 1/2" NPT / MF